

**CITY OF ANTIGO**  
**ANTIGO WATERWORKS, PWS ID: 73400866**

**2022 ANNUAL CONSUMER CONFIDENCE REPORT**  
**TESTING INFORMATION FOR 2021**

The City of Antigo is committed to providing residents with a safe and reliable supply of high-quality drinking water. We test our water using sophisticated equipment and advanced procedures. City of Antigo water meets state and federal standards for both appearance and safety. This annual “Consumer Confidence Report,” required by the Safe Drinking Water Act (SDWA), explains to you where your water comes from, what our tests show about it, and other things you should know about drinking water. All testing required by SDWA is on file and available at the water treatment facility.

Este informe contiene informacion importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Dlaim ntawv tshaabzu nuav muaj lug tseemceeb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ub tug kws paub lug thaam.

### **Water System Information**

If you would like to know more about the information contained in this report, please contact Tom Horswill at 715-627-2710.

### **Opportunity for input on decisions affecting your water quality**

The City Council meets the second Wednesday of each month at 6:00 pm.

### **Health Information**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s safe drinking water hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency’s Safe Drinking Water Hotline (1-800-426-4791).

### **Source(s) of Water**

<u>Source Id</u>	<u>Source</u>	<u>Depth (in feet)</u>	<u>Status</u>
15	Groundwater	61	Active
18	Groundwater	62	Active
19	Groundwater	76	Active
20	Groundwater	95	Active

To obtain a summary of the source water assessment please contact, Tommy Horswill at (715) 623-2710

## Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

## Key to Table

In the table on the last page, you will find many terms and abbreviations you might not be familiar with. The definitions for these tables are listed below.

## Definitions

<b>Term</b>	<b>Definition</b>
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAL	Health Advisory Level: The concentration of a contaminant which, if exceeded poses a health risk and many require a system to post a public notice.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking

water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG** Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**mrem/year** millirems per year (a measure of radiation absorbed by the body)

**NTU** Nephelometric Turbidity Units

**pCi/l** picocuries per liter (a measure of radioactivity)

**ppm** parts per million, or milligrams per liter (mg/l)

**ppb** parts per billion, or micrograms per liter (ug/l)

**ppt** parts per trillion, or nanograms per liter

**ppq** parts per quadrillion, or picograms per liter

**SMCL** For contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.

**TCR** Total Coliform Rule

**TT** Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

### Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables along with the sample date.

### Disinfection Byproducts

CONTAMINANT (UNITS)	SITE	MCL	MCLG	LEVEL FOUND	RANGE	DATE OF SAMPLE*	VIOLATION	TYPICAL SOURCE OF CONTAMINANT
TTHM (ppb)	D-20	80	0	11.0	11.0		NO	By-product of drinking water chlorination
HAA5 (ppb)	D-20	60	60	2	2		NO	By-product of drinking water chlorination

### Inorganic Contaminants

CONTAMINANT (UNITS)	SITE	MCL	MCLG	LEVEL FOUND	RANGE	DATE OF SAMPLE*	VIOLATION	TYPICAL SOURCE OF CONTAMINANT
BARIUM (ppm)		2	2	0.006	0.006		NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	0.8	0.8	2/19/2020	NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

NITRATE (ppm) (N03-N)		10	10	4.85	3.00-5.20		O	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SODIUM (ppm)		n/a	n/a	8.50	8.50	2/19/2020	NO	n/a

CONTAMINANT (UNITS)	ACTION LEVEL	MCLG	90TH PERCENTILE LEVEL FOUND	# OF RESULTS	DATE OF SAMPLE*	VIOLATION	TYPICAL SOURCE OF CONTAMINANT
COPPER (ppm)	AL=1.3	1.3	0.0450	0 of 20 results were above the action level	8/27/2020	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	7.50	0 of 20 results were above the action level	8/27/2020	NO	Corrosion of household plumbing systems; Erosion of natural deposits

### Synthetic Organic Contaminants including Pesticides and Herbicides

CONTAMINANT (UNITS)	SITE	MCL	MCLG	LEVEL FOUND	DATE OF RANGE	SAMPLE*	VIOLATION	TYPICAL SOURCE OF CONTAMINANT
ATRAZINE (ppb)		3	3	0.0	0.0		NO	Runoff from herbicide used on row crops
DI (2-ETHYLEHEXYL) PHTHALATE (ppb)		6	0	0.6	0.6	2/8/17	NO	Discharge from rubber and chemical factories

### Contaminants with a Health Advisory Level or a Secondary Maximum Contaminant Level

The following tables list contaminants which were detected in your water and that have either a Health Advisory Level (HAL) or a Secondary Maximum Contaminant Level (SMCL), or both. There are no violations for detections of contaminants that exceed Health Advisory Levels, Groundwater Standards or Secondary Maximum Contaminant Levels. Secondary Maximum Contaminant Levels are levels that do not present health concerns but may pose aesthetic problems such as objectionable taste, odor, or color. Health Advisory Levels are levels at which concentrations of the contaminant present a health risk.

CONTAMINANT (UNITS)	SITE	SMLC (ppm)	HAL (ppm)	LEVEL FOUND	DATE OF RANGE	SAMPLE*	TYPICAL SOURCE OF CONTAMINANT
CHLORIDE (PPM)		250	0	26.00	26.00	8/31/2020	Runoff from herbicide used on row crops
SULFATE (PPM)		250	0	14	14.00	8/31/2020	Discharge from rubber and chemical factories

## Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations is warranted. EPA required us to participate in this monitoring.

CONTAMINANT (units)	LEVEL FOUND	RANGE	SAMPLE DATE (if prior to 2020)
METOLAHLOR (DUAL)(ppb)	0.01	0.01	

## Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Antigo Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may want to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Other Compliance

### Uncorrected Significant Deficiencies

Deficiency Description and Progress to Date	Date System Notified	Scheduled Correction Date
The drains and overflows of elevated and ground level storage facilities are not brought down to within 12 to 24 inches of the ground surface and/or are not discharged with a free air break of at least 12 inches over a splash pad, drainage inlet structure, or rip rap	0.01	0.01

## Actions Taken

Tommy Horswill is working on it and is hoping to be done by 6/3/22.

We at the City of Antigo are interested in your questions and comments. If you would care to contact us, send your questions and/or comments to:

City of Antigo  
Water & Sewer Utilities  
700 Edison St  
Antigo, WI 54409  
715-623-3633 ext. 106

Website [www.antigo-city.org](http://www.antigo-city.org)  
Email [water.sewer@antigo-city.org](mailto:water.sewer@antigo-city.org)

Infrastructure Alternatives  
Tom Horswill 715-627-2710

This report is available at the Antigo Public Library, the Antigo Water and Sewer Department in City Hall, and [www.antigo-city.org](http://www.antigo-city.org). You may also call us at 715-623-3633, ext. 106 to request a copy.

